

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7690-0531:112 Page 1 of 1

CATEGORY: Sprinkler Heads

LISTEE: Victaulic Company of America, PO Box 31, Easton PA 18042-0031
Contact: Mike John *(610) 559-3300 *Fax (610) 923-3095

DESIGN: Models V-27, V-34 and V-38 sprinkler heads. Models V-27 and V-34 upright and pendent wax-coated, lead-coated, wax over lead-coated, and polyester painted corrosion resistant sprinklers.

Model V-27, 3/8" and 1/2" orifice upright, pendent and recessed pendent, 1/2" horizontal sidewall, vertical sidewall, and recessed horizontal sidewall.

Model V-34, 17/32" orifice upright pendent, recessed pendent, horizontal sidewall and recessed horizontal sidewall.

Model V-34, 5/8" orifice pendent and upright sprinklers.

Model V-38, 1/2" orifice concealed sprinkler.

Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as automatic sprinkler heads for use with fire sprinkler systems.

*Rev. 08-21-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

AUGUST 21, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager